

Division of Environment
Bureau of Water
Public Water Supply Section
Curtis State Office Building
1000 SW Jackson - Suite 420
Topeka, KS 66612



Phone: 785-296-5514
Fax: 785-559-4258
www.kdheks.gov

Susan Mosier, MD, Secretary

Department of Health & Environment

Sam Brownback, Governor

CONSUMER CONFIDENCE REPORT
CERTIFICATE OF DELIVERY

PWS NAME: CITY OF OVERBROOK
PWS ID: KS2013903

The community public water supply system named above hereby confirms that its annual consumer confidence report (CCR), covering the calendar year 2016 was made available to all bill paying customers also making a good faith effort to distribute the report to non bill paying customers on 4/28/17 (date).

In addition to providing the report to its customers, the system also certifies that the report was provided to the local county health department and has provided appropriate notices of availability. Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the Kansas Department of Health and Environment.

Check all that apply:

Mail – paper copy – (provide paper copy to KDHE if not provided electronically)

Email – direct URL to CCR – URL Address: _____
(Attach copy of mail notification that CCR is available on website, and who to contact if internet is not available)

Email – CCR sent as a file attachment (attach copy of email)

Email – CCR embedded in the message (attach copy of email)

Additional delivery that satisfies "otherwise directly deliver" , (intended to cover methods not included in other methods of delivery.)
(Describe method: supplies/copies provided at 2 banks, Post Office and Library)

Certified by: Name: Jim Koger
Title: City Clerk
Address: 401 Maple St, PO Box 288 City: Overbrook Zip: 66524
Phone No: 785-665-7328
E-mail: cityclerk@overbrookks.com
Date: 5/1/17

Return to: Patti Croy
Bureau of Water
Public Water Supply Section
1000 SW Jackson; Suite 420
Topeka, KS 66612-1367
Patti.Croy@ks.gov

CITY OF OVERBROOK

Consumer Confidence Report – 2017

Covering Calendar Year – 2016



This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. If you would like to observe the decision-making process that affect drinking water quality, please call DON SCHULTZ at 785-665-7328.

Our drinking water is supplied from another water system through a Consecutive Connection (CC). Your water comes from 5 Ground Water Wells and:

Buyer Name	Seller Name
CITY OF OVERBROOK	OSAGE CO RWD 5
OSAGE CO RWD 5	CITY OF CARBONDALE
OSAGE CO RWD 5	DOUGLAS CO RWD 3
DOUGLAS CO RWD 3	CITY OF TOPEKA

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in sources water before we treat it include:
Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, livestock operations and wildlife.
Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
Pesticides and herbicides, which may come from a variety of sources such as storm water run-off, agriculture, and residential users.
Radioactive contaminants, which can be naturally occurring or the result of mining activity.
Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulation which limits the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system is required to test a minimum of 2 samples per month in accordance with the Total Coliform Rule for microbiological contaminants.

Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public.

Water Quality Data

The following tables list all of the drinking water contaminants which were detected during the 2016 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1- December 31, 2016. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old. **The bottom line is that the water that is provided to you is safe.**

Terms & Abbreviations

Maximum Contaminant Level Goal (MCLG): the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.
Maximum Contaminant Level (MCL): the "Maximum Allowed" MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Secondary Maximum Contaminant Level (SMCL): recommended level for a contaminant that is not regulated and has no MCL.
Action Level (AL): the concentration of a contaminant that, if exceeded, triggers treatment or other requirements.
Treatment Technique (TT): a required process intended to reduce levels of a contaminant in drinking water.
Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Non-Detects (ND): lab analysis indicates that the contaminant is not present.
Parts per Million (ppm) or milligrams per liter (mg/l)
Parts per Billion (ppb) or micrograms per liter (µg/l)
Picocuries per Liter (pCi/L): a measure of the radioactivity in water.
Millirems per Year (mrem/yr): measure of radiation absorbed by the body.
Monitoring Period Average (MPA): An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.
Nephelometric Turbidity Unit (NTU): a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.
Running Annual Average (RAA): an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.
Locational Running Annual Average (LRAA): Average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Testing Results for: CITY OF OVERBROOK

Regulated Contaminants	Collection Date	Your Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
ARSENIC	9/9/2015	1.3	1.3	ppb	10	0	Erosion of natural deposits
BARIUM	9/9/2015	0.081	0.081	ppm	2	2	Discharge from metal refineries
FLUORIDE	9/9/2015	0.83	0.83	ppm	4	4	Natural deposits; Water additive which promotes strong teeth.
NITRATE	5/16/2016	0.16	0.16	ppm	10	10	Runoff from fertilizer use
SELENIUM	9/9/2015	4.2	4.2	ppb	50	50	Erosion of natural deposits

Disinfection Byproducts	Monitoring Period	Your Highest RAA	Range (low/high)	Unit	MCL	MCLG	Typical Source
TTHM	2015	5	4.8	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Monitoring Period	99 th Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2012 - 2014	0.4	0.034 - 0.7	ppm	1.3	0	Corrosion of household plumbing
LEAD	2012 - 2014	4.7	1.2 - 46	ppb	15	1	Corrosion of household plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Radiological Contaminants	Collection Date	Our Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
COMBINED RADIUM (-226 & -228)	9/9/2015	3.3	3.3	PCU/L	5	0	Erosion of natural deposits

Secondary Contaminants-Non Health Based Contaminants-No Federal Maximum Contaminant Level (MCL) Established.	Collection Date	Your Highest Value	Range (low/high)	Unit	SMCL
ALKALINITY, TOTAL	9/9/2015	270	270	MG/L	300
ALUMINUM	9/9/2015	0.013	0.013	MG/L	0.05
CALCIUM	9/9/2015	35	35	MG/L	200
CHLORIDE	9/9/2015	180	180	MG/L	250
CONDUCTIVITY @ 25 C UMHO/CM	9/9/2015	1200	1200	UMHO/CM	1500
CORROSIVITY	9/9/2015	0.061	0.061	LANG	0
HARDNESS, TOTAL (AS CaCO3)	9/9/2015	130	130	MG/L	400
IRON	9/9/2015	0.1	0.1	MG/L	0.3
MAGNESIUM	9/9/2015	12	12	MG/L	150
MANGANESE	9/9/2015	0.0096	0.0096	MG/L	0.05
PH	9/9/2015	7.6	7.6	PH	8.5
PHOSPHORUS, TOTAL	9/9/2015	2	2	MG/L	5
POTASSIUM	9/9/2015	2.1	2.1	MG/L	100
SILICA	9/9/2015	18	18	MG/L	50
SODIUM	9/9/2015	220	220	MG/L	100
SULFATE	9/9/2015	42	42	MG/L	250

During the 2016 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Comments
1/1/2015 - 12/31/2016	TOTAL HALOACETIC ACIDS (THAA5)	FAILURE TO MONITOR
1/1/2016 - 12/31/2016	TRIHALOMETHANES-TTHM	FAILURE TO MONITOR
1/1/2016 - 12/31/2016	PUBLIC NOTICE	PUBLIC NOTICE RULE LINKED TO VIOLATION
1/1/2016 - 12/31/2016	PUBLIC NOTICE	PUBLIC NOTICE RULE LINKED TO VIOLATION

Some or all of our drinking water is supplied from another water system. The table below lists all of the drinking water contaminants, which were detected during the 2016 calendar year from the water systems that we purchase drinking water from.

Regulated Contaminants	Collection Date	Water System	Your Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
ATRAZINE	7/18/2016	CITY OF CARBONDALE	1.6	1.6	ppb	3	3	Runoff from herbicide used on row crops
BARIUM	4/11/2016	CITY OF CARBONDALE	0.078	0.078	ppm	2	2	Discharge from metal refineries
FLUORIDE	7/11/2016	CITY OF TOPEKA	0.6	0.43 - 0.6	ppm	4	4	Natural deposits; Water additive which promotes strong teeth.
NITRATE	6/23/2016	CITY OF TOPEKA	1.6	1.6	ppm	10	10	Runoff from fertilizer use
SELENIUM	5/9/2016	CITY OF TOPEKA	1.6	1.6	ppb	50	50	Erosion of natural deposits

Secondary Contaminants	Collection Date	Water System	Your Highest Value	Range (low/high)	Unit	SMCL
ACETOCHLOR	6/21/2016	CITY OF TOPEKA	0.74	0.74	UG/L	
ALKALINITY, TOTAL	4/11/2016	CITY OF CARBONDALE	110	110	MG/L	300
ALUMINUM	5/9/2016	CITY OF TOPEKA	0.039	0.039	MG/L	0.05
CALCIUM	5/9/2016	CITY OF TOPEKA	45	45	MG/L	200
CHLORIDE	5/9/2016	CITY OF TOPEKA	30	30	MG/L	250
CONDUCTIVITY @ 25 C UMHO/CM	5/9/2016	CITY OF TOPEKA	410	410	UMHO/CM	1500
CORROSIVITY	5/9/2016	CITY OF TOPEKA	1.5	1.5	LANG	0
DESETHYLATRAZINE	6/21/2016	CITY OF TOPEKA	1.3	1.3	UG/L	
DES-ISOPROPYL-ATRAZINE	6/21/2016	CITY OF TOPEKA	0.4	0.4	UG/L	
HARDNESS, TOTAL (AS CaCO3)	5/9/2016	CITY OF TOPEKA	140	140	MG/L	400
IRON	9/9/2015	OSAGE CO RWD 5	0.37	0.37	MG/L	0.3
MAGNESIUM	4/11/2016	CITY OF CARBONDALE	8.3	8.3	MG/L	150
MANGANESE	4/11/2016	CITY OF CARBONDALE	0.0039	0.0039	MG/L	0.05
METOLACHLOR	6/21/2016	CITY OF TOPEKA	6.9	6.9	ppb	
METRIBUZIN	6/21/2016	CITY OF TOPEKA	0.31	0.31	UG/L	
PH	5/9/2016	CITY OF TOPEKA	9.6	9.6	PH	8.5
PHOSPHORUS, TOTAL	5/9/2016	CITY OF TOPEKA	0.38	0.38	MG/L	5
POTASSIUM	5/9/2016	CITY OF TOPEKA	6.9	6.9	MG/L	100
SILICA	5/9/2016	CITY OF TOPEKA	9.8	9.8	MG/L	50
SODIUM	5/9/2016	CITY OF TOPEKA	31	31	MG/L	100
SULFATE	5/9/2016	CITY OF TOPEKA	80	80	MG/L	250
TDS	5/9/2016	CITY OF TOPEKA	260	260	MG/L	500
ZINC	4/11/2016	CITY OF CARBONDALE	0.0064	0.0064	MG/L	5

Please Note: Because of sampling schedules, results may be older than 1 year.

During the 2016 calendar year, the water systems that we purchase water from had the below noted violation(s) of drinking water regulations.

Water System	Analyte	Compliance Period	Comments
CITY OF CARBONDALE	TOTAL CARBON	1/1/2016-3/31/2016	DID NOT MEET THE REQUIRED RUNNING ANNUAL AVERAGE (RAA) REMOVAL RATIO
CITY OF CARBONDALE	TOTAL CARBON	4/1/2016-6/30/2016	DID NOT MEET THE REQUIRED RUNNING ANNUAL AVERAGE (RAA) REMOVAL RATIO
CITY OF CARBONDALE	TOTAL CARBON	7/1/2016-9/30/2016	DID NOT MEET THE REQUIRED RUNNING ANNUAL AVERAGE (RAA) REMOVAL RATIO
CITY OF CARBONDALE	TOTAL CARBON	10/1/2016-12/31/2016	DID NOT MEET THE REQUIRED RUNNING ANNUAL AVERAGE (RAA) REMOVAL RATIO
OSAGE CO RWD 5	TRIHALOMETHANES-TTHM	7/1/2016-9/30/2016	EXCEEDED MAXIMUM CONTAMINANT LEVEL (MCL)
OSAGE CO RWD 5	TRIHALOMETHANES-TTHM	10/1/2016-12/31/2016	EXCEEDED MAXIMUM CONTAMINANT LEVEL (MCL)
DOUGLAS CO RWD 3	TRIHALOMETHANES-TTHM	4/1/2016-6/30/2016	EXCEEDED MAXIMUM CONTAMINANT LEVEL (MCL)